PENTAIR

AUROR

NOTE! To the installer: Please make sure you provide this manual to the owner of the equipment or to the responsible party who maintains the system.

i. Flange adapter gaskets are not interchangeable with other flange adapters.

HANDLE TURNS INDICATOR POSITION:

To adjust the handle turns indicator position to enable easier access for viewing:

1. Fully close the valve.
2. Remove the handle retaining bolt at the hub of the handle.
3. Pull the handle straight from the valve stem (tap gently with a soft mallet if required).
4. For models with:
   a. Plastic handles; rotate the handle and turns indicator assembly (retaining a turns indication of 0.0) and replace the handle onto the valve stem.
   b. Cast iron handles; loosen the brass knurled turns indicator retaining ring, rotate the turns indicator to desired position, retighten the retaining ring by hand (do not over-tighten), and replace the handle on the valve stem.
5. Insert and tighten the valve handle retaining bolt.
6. Open the valve to ensure the handle turns freely and turns indicator reads properly.

OPERATION:

1. If an alternate technology flowmeter is used, refer to the instructions supplied for taking flow measurements.
2. For variable orifice flow measurement using the differential pressure developed across the valve seat, remove the PT

WARRANTY

Seller warrants equipment (and its component parts) of its own manufacture against defects in materials and workmanship under normal use and service for one (1) year from the date of installation or start-up, or for eighteen (18) months after the date of shipmeshichever occurs first. Seller does not warrant accessories or components that are not manufactured by Seller; to the extent possible, Seller agrees to assign to Buyer its rights under the original manufacturer's warranty without recourse to Seller Buyer must give Seller notice in writing of any alleged defect covered by this warranty (together with all identifying including the serial num thpeyof equipm the date of purchase) within thirty (30) days of the v ery of such defect during the y period. No claim made more than 30 days afte