



_____ – Pump shall be Myers Model Number 3WHV/V3WHV Solids Handling Submersible Pump with 2- vane enclosed impeller. All openings in pump impeller and volute case to be large enough to pass a 2-1/2" diameter sphere. Discharge flange shall be three (3) inch standard.

–